

No. Fail: JBPM/IP/RNP:700-7/2/7-484 (4)
(PEMBAHARUAN PERTAMA)

SIJIL PEPASANGAN KESELAMATAN KEBAKARAN

APPROVAL CERTIFICATE

Jabatan Bomba dan Penyelamat Malaysia
dengan ini memperakukan
Fire and Rescue Department of Malaysia
hereby certify

BAHAN KELAS 'O'
(ALUMINIUM COMPOSITE PANEL) PE CORE


Berdasarkan Piawaian
Complying with

BS 476:PART 6:1989+A1:2009 & BS 476:PART 7:1997

Syarikat Berdaftar
Registered company

MBOND MANUFACTURER SDN BHD (1077474-A)
No.9 Jalan TPP 3,
Taman Perindustrian Putra,
47130 Puchong,
Selangor DE.

Tempoh sah perakuan: **02/02/2022 hingga 01/02/2024**


(KAMARULZAMAN MALIK ABDULLAH)
Pegawai
Bahagian Perancangan dan Penyelidikan,
b.p. Ketua Pengarah
Jabatan Bomba dan Penyelamat Malaysia.

Tarikh: **11 Januari 2023**

**** Peringatan:**

Sila patuhi sepenuhnya syarat-syarat dan had kegunaan seperti dalam Lampiran A1



CERTIFIED TO ISO 9001:2015
CERT. NO QMS 02101



CERTIFIED TO ISO 37001:2016
CERT. NO ABMS 00216

No. Fail: **JBPM/IP/RNP:70Q-7/2/7-484 (4)**

No.Siri: **BB/CO/2120/2016 (P1)**

LAMPIRAN A1

Jenis Bahan Binaan	: ALUMINIUM COMPOSITE PANEL (POLYETHYLENE CORE)
Jenama & Spesifikasi	: 'MBOND' (PE CORE) Thickness: 4.0mm (7.59 kg/m²) (mass per unit area)
Nama & Alamat Pengeluar	: MBOND MANUFACTURER SDN BHD
Tahap Rintangan Api	: CLASS 'O'
No. Laporan ujian/Tarikh	: SIRIM 2015FE0001 (22/01/2015), 2015FE0002 (22/01/2015), 2019FE0301 (28/05/2019) & 2019FE0300 (28/05/2019)
Skim Persijilan Barangan	: SIRIM QAS INT. NO. PC004414 (NO.SIRI 073304) SAH SEHINGGA 31/05/2023
Had Kegunaan	: PEMASANGAN 'CLADDING' TERHAD KEPADA BANGUNAN BERKETINGGIAN <u>18 METER KE BAWAH</u> <u>SAHAJA</u>. HENDAKLAH MEMATUHI SPESIFIKASI UJIAN, UBBL 1984 SERTA SYARAT-SYARAT TAMBAHAN SEPERTI DI LAMPIRAN A2 & A3.

Tempoh sah perakuan: **02/02/2022 hingga 01/02/2024**

